



An ISO 9001 : 2000 company

सर्टिफिकेशन इंजीनियर्स इंटरनेशनल लिमिटेड

(इंजीनियर्स इंडिया लिमिटेड, भारत सरकार का उपक्रम, की सहायक कंपनी)

CERTIFICATION ENGINEERS INTERNATIONAL LTD.

(A wholly owned subsidiary company of ENGINEERS INDIA LIMITED, A Govt. of India Undertaking)

Head Office: D/101 - 106, First Floor, ITC, CED Relajar Station Complex, Navi Mumbai - 400 614.
Tel : 91-22-4795 8700 • Fax : 91-22-4795 8701 / 2 • E-mail : ceilnub@vsnl.net
Regd. Office: Engineers India Bhawan, I, Block, Conna Place, R. K. Puram, New Delhi - 110 066.
Tel : 91-11-2610 2121, 2610 1265 • Fax : 91-11-2616 4868, 2618 6245 • Email : ceil.del@eil.co.in
Website : <http://www.certificationengineers.com>

INSPECTION REPORT

REPORT NO. : CEIL/ 9308/NKS/742 DATE : 26.06.2010
PROJECT/CUSTOMER : Type Test/Comfit & Valves PLACE OF ISSUE : Mehsana
CONTRACTOR : - JOB NO. : 9308
VENDOR/SUB-VENDOR : Comfit & Valves (P) Ltd. LOCATION : Mehsana
PURCHASE ORDER NO. : MOM with CEIL DATE OF P.O. : 30 April 2010


THIS INSPECTION REPORT WILL BE FOLLOWED BY AN INSPECTION CERTIFICATE/RELEASE NOTE AFTER SATISFACTORY COMPLETION OF ALL INSPECTIONS

P.O. SR. NO.	ITEM DESCRIPTION	UNIT	QUANTITY		
			AS PER P.O.	OFFERED	RELEASED
	Instrument tube fittings, Instrument Needle valves, Instrument Manifold Valves, & Ball Valves As list attached, Annexure '1' duly signed and sealed	Lot	Lot	Lot	Lot

REFERENCE DOCUMENTS : 1) EIL Standard spec 6-52-0067 Rev '3' & 6-52-0069 Rev 3
2) BS 4368 : Part 4 :1984
3) MSS - SP - 99 - 1994


VERIFICATIONS/CHECKS CARRIED OUT & OBSERVATIONS: Type test conducted as per BS 4368 Rev '4' for tube fittings and MSS-SP-99-1994 for Valve and manifolds. Following tests were conducted :
1) Raw Material Identification and review of TC for raw material
2) Conducted Hydro test / Pneumatic test / Pressure test / Vacuum test of Tube Fittings.
3) Hydraulic Impulse and vibration test
4) Pneumatic and Hydrostatic test and Burst Pressure test for Needle Valves, Ball valves and Instrument manifolds Valves.

REMARK: Type test results conform compliance of tube fittings as per BS 4368 part 4-1994. For valves and manifolds as per MSS-SP-99-1994 & EIL STD referred above.

SIGNATURE:  DATE: 26.06.10

VENDOR REP'S NAME: Jeetu Jain, Comfit Valves (P) Ltd

File No.:

SIGNATURE:  DATE: 26.06.10

CEIL SURVEYOR'S NAME: N.K.Sanyal

F-001-R-4

THIS DOCUMENT IS THE PROPERTY OF ENGINEERS INDIA LIMITED. IT IS TO BE USED ONLY FOR THE PURPOSES FOR WHICH IT IS ISSUED. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE PRIOR WRITTEN PERMISSION OF ENGINEERS INDIA LIMITED.